

CITY OF BLAINE UTILITIES DEPARTMENT

SEWER BACK UP REPORT

Date: 07-28-19

Address: 11841 3rd St

Time call was received 8:00 pm Time PW arrived on scene 8:30 pm

Time jetter arrived 8:30 pm Blockage between manhole # 182 & 185 and # 181

What was the footage to blockage 100 from manhole # 182

Time blockage was cleared 10:45 pm

Size and type of sewer main 8"

Cause of Blockage Sticks/Branches from Trees causing toilet Paper

Weather Conditions: Light Rain Temp.: 75°
Built up

Personnel: Jake Skorsech, Chad Frerichs

Equipment: Vac Truck & Ford 4x4 Pick up 4487

Report:

Upon Arrival M.H. #181 was almost full. After jetting broke
through the blockage it was clear to us that someone
has been pushing sticks through the hole of the M.H. cover
down into the sewer causing the back up.

Reported by: Jake Skorsech

Has this section of pipe previously been televised? When? Reason

Have there been prior back ups in this area? Date/Reason

Last time main was jetted?