

Note: This proposal may be withdrawn if not accepted within 45 days.

225 Bridgepoint Drive South St. Paul, MN 55075 Ph: 651- 292-9933

Fax: 651-292-9929

3932		
Proposal Date	Date of Site Visit	Proposal Number
5/11/2016	5/5/2016	S16360
GUBMITTED TO: McGough Facility Management 2737 Fairview Avenue North Roseville, Minnesota 55113 ATTENTION: Brian Jasken	PHONE: (651) 248-1048 bjasken@mcgough.com	PROJECT NAME AND LOCATION: Compressor Replacement Blaine City Hall Blaine, Minnesota
60	NTRACTOR WILL PROVIDE THE	EOLLOWING:
 Refrigerant recovery of e Rigging to remove old a Provide one(1) Daikin M Replacement of existing Evacuate system and re Check, test and start-up One year parts and labo 	nd set new compressor IR350310731 compressor including I liquid line filter drier cores Incharge with 160# of new R-22 refri I of chiller I warranty	freight and return old compressor for core credit
Note: Compressor is fac	etory remanufactured stock at factory. Allow 3-5 days deli	
	51) 292-9933 with any questions or	
Il material is guaranteed to be as specified. All work		
deviation from above specifications involving extra		
0% down payment is due with signed orde		IS THE TERMS AND CONDITIONS ATTACHED TO THIS PROPOSAL. MENT to be made as invoiced terms net 10 days.
ONTRACTOR: Schadegg Mechanical	<u>CUSTOMER</u>	: McGough Facility Management
		Signature:
John L. Noe LEED AP, Service I	Manager	Name:

Date:





1001 Labore Industrial Court, Suite B Vadnais Heights, Minnesota 55110

tel: 651-490-9868 fax: 651-490-1636

May 8, 2016

Mr. Brian Jaskens Blaine City Hall 10801 Town Square Drive NE Blaine, MN 55449

RE: Chiller Compressor Issue

Current Situation: The compressor #3 on the building chiller has failed and the unit will not operate and properly cool the building until it is replaced.

Proposed Solution: NAC proposes to replace the compressor with a factory replacement compressor per the scope below.

Scope of Work:

- Disconnect and remove the existing compressor, return for core credit.
- > Hoist the new compressor and reconnect the power, refrigeration lines and controls.
- Install a suction line shell(s) and filters to provide acid clean up.
- Install acid clean up liquid line filters, replace oil filter.
- Evacuate and leak test system.
- Install new refrigerant (old refrigerant with acid contamination will be recycled per EPA Standards).
- Start and test the unit for proper operation.
- > Return after a period of time (based on weather temperature), acid test oil.
- Replace oil, oil filter, liquid line filter and suction line filter with permanent filters, if acid is removed from the system. If acid is still present, see note below.
- Clean up any related materials.

Customer Base Investment: Investment: \$56,987.00

Notes:

- Any work beyond the above scope will be quoted for your approval prior to NAC proceeding.
- If additional acid cleanup is required (doubtful), additional acid clean up filter replacement will be quoted.

Pricing is subject to change after 30 days based on fluctuations in equipment, refrigerant or materials cost.

Accepted by:		
NAC Mechanical 8	Electrical Services	Brian Jaskens
Signature:	Charlie Kistler	Signature:
Name:	Charlie Kistler	Name:
Title:	Service Representative	Title:
Date:	May 8, 2016	Date:

www.nac-hvac.com, 24 Hour Service
An Affirmative Action, Equal Employment Opportunity Employer
Direct (651) 255-3523 Fax (651) 490-1636 Cell (651) 230-7729 Email ckistler@nac-hvac.com