

City of Blaine Anoka County, Minnesota

Legislation Details (With Text)

File #:	МО	19-171	Version:	1	Name:	Approve Purchase of Repair Stataion 12 & 13	Components for Lift
Туре:	Moti	ion			Status:	Passed	
File created:	10/7	/2019			In control:	City Council	
On agenda:	10/7	/2019			Final action:	10/7/2019	
Title:	APPROVE PURCHASE OF REPAIR COMPONENTS FOR LIFT STATIONS #12 AND #13						
Sponsors:	Jon	Haukaas					
Indexes:							
Code sections:							
Attachments:							
Date	Ver.	Action B	у		Ac	tion	Result
10/7/2019	1	City Cou	uncil		Ар	proved	

CONSENT AGENDA - Jon Haukaas, Director of Public Works

APPROVE PURCHASE OF REPAIR COMPONENTS FOR LIFT STATIONS #12 AND #13

Staff has been conducting comprehensive inspections of all our lift stations as we progress through the SCADA upgrade project. As a result of these inspections, lift stations 12 and 13 were found to have severely deteriorated components.

Lift station #12 Pump #1 needs an impeller, wear ring and slide bracket Pump #2 needs impeller and wear ring. Total for lift #12 = \$19,140

Lift station #13 Pump #2 needs an impeller & wear ring Pump #1 needs a slide bracket only Total for lift #13 = \$11,770.00

Total for both stations = 30,910.00

This price is for the component parts only. Installation will be completed by staff.

While this is not yet an emergency repair, staff feels that it is vital this rehab occur as soon as possible to reduce the risk of total failure of the station.

Sufficient funds are available in the Sewer Enterprise Fund to accommodate this purchase.

By motion, approve payment of \$30,910.00 to W.W. Goetch Associates for repair components to Lift Stations 12 &13.